



1. Solar Power Forecasting Techniques: Review

Debjani Dutta Gupta

Siksha 'O' Anusandhan University, Bhubaneswar, India.

Prarthana Mohanty

Kalinga Institute of Technology, Bhubaneswar, India.

ABSTRACT

The rising interest for energy is perhaps the most compelling motivation behind the combination of sun powered energy into the electric frameworks or organizations. To guarantee the productive utilization of energy PV frameworks it becomes critical to estimate data dependably. The exact expectation of sun oriented irradiance variety can improve the nature of administration. This reconciliation of sun powered energy and precise forecast can help in better preparation and dissemination of energy. Here in this paper, a profound audit of techniques which are utilized for sun powered irradiance determining is introduced. These strategies help in choosing the fitting gauge method as indicated by the necessities or prerequisites.

KEYWORDS:

Solar forecasting, physical method, statistical method, hybrid methods.

I. Introduction:

In recent times, the growing population and increased demand of energy in every field of development is leading to reduction of energy coffers like coal, petroleum, natural gas etc. The world reserves of these exhaustible coffers are depleting fleetly. Redundant use of non-renewable coffers also leads to environmental issues like pollution. Non-renewable energy sources leave behind dangerous remainders which beget numerous problems, like during canvas drilling in abysses, canvas tumbles can take place which kills numerous oceanic brutes.

Burning of coal leads to product of redundant carbon monoxide and carbon dioxide which eventually leads to hothouse effect and global warming. Also, burning of petroleum produces dangerous chemicals like lead which creates health problems in humans and creatures. As a whole, using non-renewable energy coffers perhaps easier but its further dangerous. This is paving the way for increased demand for renewable energy coffers like solar, hydro, wind, and tidal powers.

These types of powers are safe to use, it's not dangerous in any way and they're available in cornucopia directly from the nature. The renewable energy sources are a bit delicate to tap, they need further technology to use that's why they're expensive to manage and maintain. This is the reason why experimenters are chancing this field full of openings because there's still a lot of progress to be made. Vaticinating solar energy generation is a grueling field. Because of the unorganized and unreliable nature of the rainfall, the power affair of PV energy systems is monstrously uncertain. Due to the spastic and willful nature of solar power, the precise cast of solar power generation is veritably pivotal for the solar electric power force companies. To get the stylish profitable benefit from a PV system, it's essential to design an algorithm for the vaticination of the affair power of a PV system.

The other factors affecting affair power being temperature, moisture, wind speed, and dust. Numerous exploration papers have portrayed the use of time series models and numerous machine literacy models like ARMA, ARIMA, MA, ANNs to get algorithms that find accurate results and help in perfecting exploration work in this field. It's been proven that Artificial Neural Networks (ANNs), Support Vector Machines (SVMs) work much better and faster than time series models.

There are certain areas of the world which still bear a lot of development. Further growth in these vacated areas where further solar energy can be tapped will lead to the whole world being powered fluently. The areas that have high average solar irradiation should be equipped with better technology solar panels that will be salutary for further energy tapping. For effective and briskly solar soothsaying we need to develop better algorithms and models using machine literacy ways.

II. Solar Forecasting Methods:

Load forecasting has become an integral process in the planning and operation of electric utilities, system operators, and other market participants as deregulated electricity markets have become more common, with their high costs of over or under contracting and buying or selling power in the balancing market. Solar irradiation varies dramatically over a short period of time, making it difficult to predict how much output power will be injected into the grid. Short-term PV power forecasting assists load dispatching, planning, and regulatory actions during the operation of a solar power plant. In the current scenario, the energy system faces a number of issues. As energy demand rises and fossil fuel resources become scarce, the need for renewable resources has become increasingly important. Solar power forecasting that is accurate and reliable is critical to the power system's proper operation. In this paper we will be reviewing some of the recent methods used for solar power forecasting.

1. ANFIS model:

Most of the forecasting models don't include the variations of the daily weather. This RP specifically takes into account the condition of the skies into the SPV systems for forecasting of short-term solar power. Comparative analysis of symbolic logic, ANN and ANFIS models in forecasting short-term PV power of SPV systems employing HIT PV modules for various sky conditions i.e., sunny sky, hazy sky, and partially foggy/cloudy sky conditions and for composite climate zone.

Obtained results show the average mean absolute percentage error when using fuzzy logic methodology is 0.10 percent; when using ANN methodology, the mean absolute percentage error is 0.04 percent; and when using ANFIS methodology, the mean absolute percentage error is 0.01 percent, indicating that the obtained results are more precise and accurate. This is because it uses both a fuzzy logic technique and an artificial neural network.

2. ANN and GNN model:

The ANN and GNN model has been used to forecast the solar power taking into account the average temperature of a day, solar irradiation and wind velocity as the main variables/factors. The ANN model gave a RME error of 13.1 percent and the GNN model gave a RME error of 5.5 percent. By comparing the RME error percentages the GNN model performs more accurately than the ANN model. The factors taken into consideration to compute the forecast are metrological data which can be used to detect general trends and overall changes in the solar power generation but aren't very reliable when it comes to detect short term forecasting.

3. Quantum based Genetic Algorithm – Generalized Neural Network (QGA-GNN):

The neural network training data was created after a data logger was used to record the power output of a solar panel in the Department of Electrical Engineering, Faculty of Engineering, Dayalbagh Educational Institute (Deemed University), Agra, India.

Every minute, the power output was recorded. This raw data is treated to reduce undesired sensor noise before being assembled into neural network training data. This paper discusses the performance of neural networks for solar power forecasting. The simple neural approach has certain problems such as issues related to the selection of network structure /architecture, its training, and the optimal use of training data. To overcome some of these problem's Quantum GA-GNN was proposed. The model gave a RMS error of 0.6 percent with non-filtered data and 0.5 percent with filtered data. These models give a good RMS score on filtered and pre-processed data. The accuracy score falters when used on un-processed data. Real world data is expected to be unorganized and not processed, so this is one limitation. This model most probably could not be used on real time data.

4. ELM technique:

ELM is a single hidden layer feed-forward Neural Network which arbitrarily chooses the input loads and edges and decides the result loads through framework calculation. It is hypothetically equipped for approximating any ceaseless capacity and executing any classification application. It stays away from the conventional slope based calculations which are utilized in Back-Propagation Neural Network calculations to tune the loads.

The extreme learning machine is a training algorithm that doesn't need iterative tuning while ensured to reach global minima. It is inferred that ELM preparing speed is by and large quicker than gradient-descent based preparing calculation. It can try not to pick extra boundaries, for example, the learning rate and stopping criterion.

Exact proof shows that ELM has great speculation and general estimate capacities. It is expressed that the littlest standard of loads will have better speculation execution which can be achieved with ELM. It tends to the long training time of Back Propagation (BP) while holding its generalization and universal approximation abilities.

5. Hybrid EMD-ELM Method:

As compared to the classical forecasting method the ELM forecasting method has better generalized forecasting performance with a RMSE of 11.7 percent. By the application of the EMD algorithms, the proposed hybrid EMD-ELM forecasting technique can boost the forecasting performance of the ELM. The logic behind this situation is that the application of EMD algorithms provide efficient handling of natural data, giving small nonlinear time varying input data to ELM so that the built ELM model can realize the high accuracy forecasting with less error and among these two methods, the proposed hybrid EMD-ELM technique has the best forecasting performance in the solar power forecasting with a RMSE of 7.04 percent. Both models give their forecast based on data collected immediately in 5 minutes, making this model a real time solution for forecasting of solar power.

6. GASVM Technique:

A genetic algorithm-based help vector machine (GASVM) model for transient power estimating of private scale PV framework. The GASVM model groups the authentic climate information utilizing a SVM classifier at first and later it is enhanced by the hereditary calculation utilizing an ensemble technique. In this examination, a nearby weather conditions station was introduced alongside the PV framework at Deakin University for precisely observing the prompt general climate staying away from the incorrectness brought about by the distant assortment of climate boundaries (Bureau of Meteorology). The anticipating precision of the proposed GASVM model is assessed in light of the root mean square error (RMSE) and mean absolute rate percentage error (MAPE). Test results exhibited that the proposed GASVM model beats the customary SVM model by the distinction of around 669.624 W in the RMSE value and 98.7648 percent of the MAPE error. The utilization of true ecological information from a city like Geelong with differentiated weather conditions helps in assessing and working on the exactness of demonstrating the GASVM ensemble technique. The proposed model enormously improves on the issue for future assessments of various areas without requiring a point by point study on the connections of the PV board, neighborhood climate, and climatic pattern.

7. Physical Methods:

A. Cloud Imagery and Satellite Based Models:

The concept of the cloud symbolism-based model is that it utilizes the satellite's high spatial goal to manage the darkness and find the place of clouds. It also helps in determining the exact location of clouds. The boundaries of clouds and the cover of clouds are the most important factors that affect the irradiance of sunlight at the surface. In this model, the advantages include high-resolution images and good historical data. The disadvantages, on the other hand, are the high cost, the possibility of clouds obscuring certain ground features, fixed schedules, and the need to eliminate and find the correct image or data.

B. Physical Satellite Models:

A satellite model's premise of determining sun-oriented irradiance relies on communication between the sun-based radiation and the barometrical components, such as gases and vapor sprayers. In a follow-up step, actual satellite models are supposed to be further developed RTM based clear sky models by expanding data according to current climatic conditions. A record of climate conditions is created through the estimation of nearby meteorological information. This obviates the need for sun-oriented irradiance data at the surface, however, as these models need to change over time.

C. Statistical Satellite Models:

The models are characterized by the relapse between the pyranometer-based sunlight-based irradiance at ground level and the concurrent counts of satellite-based instruments. Different boundaries under relapse conditions include the apex of the sun, a cloud cover file, barometrical transmissivity to the extent that it exceeds the current splendor level, the least brilliance and the greatest brilliance of every pixel. While comparing satellite and ground data, two difficulties emerge. The first one is errors associated with the limitation of ground-based pyranometer locales compared to satellite images, and the second one is the key difference in estimating strategies. Certain creators suggest addressing these issues by adding more pixels to the target regions. This can be done by upgrading the satellite goal.

D. Total Sky Imagers:

As of March 2004, the Total Sky Imager (TSI) is used to predict very short-term and short-term forecasts. NWP and satellite images missed the mark on the spatial-temporal goal of giving data in regards to recurrence variances of sunlight irradiance. Ground-based imaging can provide a window into neighborhood meteorological conditions. One instrument that has recently seen increased use is Yankee Environmental Systems' Total Sky Imager (TSI). However, despite the fact these TSI-based models provide neighborhood meteorological data enabling intra-hour conjectures, their time period is restricted to roughly 30 minutes due to their limited scope. It might help to convey a variety of imagers to acquire more data on the cloud fields around the neighborhood as a way to expand the time skyline of ground-based estimations. While ground-based imaging methods can deal with the difficulties posed by the TSI's general expenses and the idea of neighborhood cloud fields, current ground-based imaging procedures may have difficulty coping with the TSI's unique aspects.

E. Wireless Sensor Network Systems:

Satellite and NWP models normally have time skylines on the request for 30 minutes while stochastic and AI strategies have not been broadly applied to time skylines under 15 minutes. TSIs are restricted by the circum-sun based dissipating of light and the shadow-band to time skylines no longer than 3 minutes. Semiconductor point sensors are able to do extremely high testing frequencies yet neglect to accurately portray the appropriated idea of a functional scale PV plant. An option has been recommended by Coimbra and associates at the University of California, Merced. A 1MW PV cluster was furnished with 40 TelosB hubs outfitted with minimal expense sun powered irradiance sensors.

The writers in proposed a determining calculation which used various readings from the spatially disseminated organization of sensors to register future upsides of the appropriated power yield. The determining approach used spatial cross-connections between sensor hubs which gave conjectures in the scope of 20-50 seconds. Determined speeds concurred with TSI determined cloud speed field more than 70 percent of the time. This work exhibits the capability of remote sensor networks as minimal expense and profoundly precise methodologies for intra-minute sun-based estimating.

F. Numerical Weather Prediction Model:

The numerical weather predictions absolutely depend upon the barometrical physical science. It is the investigation of how current perceptions of the weather conditions are utilized and afterward handled to foresee the future conditions of the climate. This is finished with the assistance of super PCs. An interaction called assimilation is done as such as to handle the current weather conditions states and produce results of temperature, wind, irradiance and different many meteorological components. The NWP is great for one day to multi-days ahead skylines. Accordingly, it is a helpful device for various assortment of utilizations, for example, the booking of sun based power plants. NWP is additionally useful in anticipating the transient varieties in mists, which are viewed as the significant obstacles for sun based irradiance at the ground.

The mathematical climate forecasts simply depend upon the air material science. It is the investigation of how current perceptions of the weather conditions are utilized and afterward handled to foresee the future conditions of the climate. This is finished with the assistance of super PCs. An interaction called assimilation is done as such as to handle the current weather conditions states and produce results of temperature, wind, irradiance and different many meteorological components. NWP and satellite figures are insufficient for accomplishing high fleeting and spatial goal for intra hour gauges. This hole can be filled by ground perception utilizing a sky imager and conveys a sub-kilometer perspective on cloud shadows over a huge scope PV power plant or a metropolitan distribution feeder.

8. Statistical Methods:

A. Time Series Model:

Time series models gives the outcome in light of the authentic information. Time series can be characterized as a grouping of perceptions estimated over the long run, like the hourly, day to day or week by week. Since the perception could be arbitrary it is moreover known as stochastic cycle.

B. Linear Stationary Model:

Observational series that portray a changing actual peculiarity with time can be grouped into two principal classifications; fixed and non-fixed. Assuming the grouping of loads is limited, or boundless and joined, the straight channel is supposed to be steady and the interaction (stochastic cycle) to be fixed. Fixed time series are static regarding their overall shape.

The variances might seem requested or totally irregular, in any case, the personality of the series is, overall, the equivalent in various fragments. Fixed time series track down applications in numerous regions of the actual sciences, for example, observational time series and series including deviations from a pattern are frequently fixed.

C. Auto-Regressive (AR) Model:

The auto-regressive (AR) models get their name from the way that the current worth of the cycle can be communicated as a limited, straight blend of the past upsides of the interaction and a solitary shock. Hence, the interaction is supposed to be relapsed on the past values.

D. Moving Average (MA) Model:

While the AR methods model the stochastic part of the time series as a weighted number of past values. Moving Average (MA) strategies model as a limited amount of n past shocks.

E. Mixed Auto-Regressive Moving Average (ARMA) Model:

An ARMA model, or Autoregressive Moving Average model, is utilized to portray feebly fixed stochastic time series as far as two polynomials. The first of those polynomials is for autoregression, the second for the moving average.

F. Non-Linear Stationary Model:

Non-linear methods would empower strong designs with the capacity to precisely portray a complex nonlinear way of behaving like chaos, hysteresis, and immersion impacts or a blend of a few non-linear issues. These non-linear models track down numerous applications in the field of design, particularly in the definition of Artificial Networks.

G. Auto-Regressive Integrated Moving Average Models (ARIMA) Model:

An autoregressive integrated moving average, or ARIMA, is a factual examination model that utilizes time-series information to either better comprehend the informational index or to anticipate future patterns. A measurable model is autoregressive in the event that it predicts future qualities in light of past qualities.

ARIMA is a relapse model. Assuming the information you're managing was produced by an interaction that acts like what's portrayed in the model detail, it's your most ideal decision. On the off chance that not, some other model is better.

H. Artificial Neural Networks:

ANNs are used to perform two kinds of assignments, which are, regression and pattern recognition. Both these are applied in solar irradiance forecasting. ANN makes two strides, the training, and the forecast. Weights for the artificial neurons are determined in the training phase, and forecasts are computed based on these weights.

An ANN instead of predicting irradiance outputs a number that represents the classification of objects. Temperature and humidity are used as meteorological and climatological inputs to improve irradiance forecasting.

9. Hybrid Methods:

As a forecasting technique, hybrid models combine two or more techniques in order to enhance accuracy. With hybrid models, the goal is to overcome the weaknesses of the individual models, take advantage of their advantages, merge them together and then provide a new hybrid model that reduces forecasting errors. By feeding the output from the NWP model into the ANN model, it can be combined with the NWP model. Integrated forecast methods outperform individual forecast methods, according to many studies. Hybrid models combine linear models with nonlinear models or nonlinear and linear models with each other.

III. CONCLUSION:

Different solar forecasting strategies and assessment measurements are talked about in this work. From the review it is observed that an assortment of work has been performed by different creators for various different spatial and worldly goals. The concentrate here is finished by different gauging techniques. If there should arise an occurrence of actual techniques different cloud symbolism and satellite-based models are considered. Aside from these two all-out sky imagers and NWP models are additionally the piece of actual strategies. Satellite imaging-based techniques is utilized as options in contrast to costly ground-based pyrometer organizations.

These are best for determining of irradiance in conditions where no different information is accessible. The main burden of these strategies is that they experience the ill effects of fleeting and spatial constraints because of satellite testing recurrence and cut-off points on spatial goal of the satellite pictures. NWP is additionally utilized for areas without broad ground organizations. These are most ideal choice for long haul anticipating with skyline from few hours to several days or more. If there should arise an occurrence of factual strategies different time series and it are considered to learn techniques. In time series techniques succession of perceptions are estimated over the long haul. These strategies have models like AR, MA, ARMA, ARMAX, ARIMA and so on What's more, in learning strategies different fake procedures are viewed as like brain organizations, hereditary calculation and so on Fake Neural Network is talked about which gives great execution to irradiance information when enough recorded information is free. These are utilized for gauging intra-hour to yearly time skylines. ANNs are nonexclusive non-direct approximators that convey minimal answers for quite a long time straight, stochastic and multivariate issues. These days, the most utilized strategy is the half and half technique which fuses at least two procedures and produces another estimating technique with further developed exactness. In this technique the lacks of the singular model is survived and benefits of individual models are used. These techniques additionally decrease the gauge blunders. For assessing the gauge blunders sun powered it are likewise contemplated to figure assessment measurements. Estimating assessment measurements permit to comprehend the amount to trust the gauge and re-examine it if there should arise an occurrence of high mistakes.

IV. REFERENCES:

1. Chaturvedi, D. K., Isha, I. (2016). Solar power forecasting: A review. *International Journal of Computer Applications*, 145(6), 28-50.
2. Abuella, M., Chowdhury, B. (2015, October). Solar power forecasting using artificial neural networks. In *2015 North American Power Symposium (NAPS)* (pp. 1-5). IEEE.
3. Theocharides, S., Makrides, G., Georghiou, G. E., Kyprianou, A. (2018, June). Machine learning algorithms for photovoltaic system power output prediction. In *2018 IEEE International Energy Conference (ENERGYCON)* (pp. 1-6). IEEE.
4. Zhang, J., Hodge, B. M., Florita, A., Lu, S., Hamann, H. F., Banunarayanan, V. (2013). Metrics for evaluating the accuracy of solar power forecasting (No. NREL/CP-5000-60142). National Renewable Energy Lab. (NREL), Golden, CO (United States).
5. Shi, J., Lee, W. J., Liu, Y., Yang, Y., Wang, P. (2012). Forecasting power output of photovoltaic systems based on weather classification and support vector machines. *IEEE Transactions on Industry Applications*, 48(3), 1064-1069.
6. Van Tai, D. (2019, October). Solar photovoltaic power output forecasting using machine learning technique. In *Journal of Physics: Conference Series* (Vol. 1327, No. 1, p. 012051). IOP Publishing.
7. Akhter, M. N., Mekhilef, S., Mokhlis, H., Shah, N. M. (2019). Review on forecasting of photovoltaic power generation based on machine learning and metaheuristic techniques. *IET Renewable Power Generation*, 13(7), 1009- 1023.
8. Theocharides, S., Venizelou, V., Makrides, G., Georghiou, G. E. (2018, June). Day-ahead forecasting of solar power output from photovoltaic systems utilising gradient boosting machines. In *2018 IEEE 7th World Conference on Photovoltaic Energy Conversion (WCPEC) (A Joint Conference of 45th IEEE PVSC, 28th PVSEC 34th EU PVSEC)* (pp. 2371-2375). IEEE.
9. Isaksson, E., Karpe Conde, M. (2018). Solar power forecasting with machine learning techniques.
10. Singh, V. P., Vaibhav, K., Chaturvedi, D. K. (2012, December). Solar power forecasting modeling using soft computing approach. In *2012 Nirma University International Conference on Engineering (NUICONE)* (pp. 1-5). IEEE.
11. Chaturvedi, D. K. (2015). Forecasting of Solar Power using Quantum GA-GNN. *Int. J. of Computer Applications*, 128(3), 15-19.
12. Majumder, I., Behera, M. K., Nayak, N. (2017, April). Solar power forecasting using a hybrid EMD- ELM method. In *2017 international conference on circuit, power and computing technologies (ICCPCT)* (pp. 1-6). IEEE.
13. Perveen, G., Rizwan, M., Goel, N. (2019). Short- term PV power forecasting based on sky-conditions using intelligent modelling techniques. *International Journal of Engineering, Science and Technology*, 11(4), 49-57.
14. VanDeventer, W., Jamei, E., Thirunavukkarasu, G. S., Seyedmahmoudian, M., Soon, T. K., Horan, B., Stojcevski, A. (2019). Short-term PV power forecasting using hybrid GASVM technique. *Renewable energy*, 140, 367-379.
15. Behera, M. K., Nayak, N. (2020). A comparative study on short-term PV power forecasting using decomposition based optimized extreme learning machine algorithm. *Engineering Science and Technology, an International Journal*, 23(1), 156-167.